

## QUESTIONS AND ANSWERS

Q.1. Page 7 - Contractor is responsible to construct a POE if does not exist or is collapsed. How is the contractor to recover those costs? Is that intended to be part of the "Over-run" policy in Attachment 1?

A.1. It is the contractors responsibility to make sure a POE exists at each location. Each location has a spare conduit heading into the building (As seen by visual inspection) but the integrity of these conduits are unknown to the UCS. If any POE construction should be required it should fall under the NRC portion of the project or its cost be calculated into the MRC. This is only in the event that a POE is required to be constructed. The UCS does not guarantee that any POE is valid. It is the responsibility of the vendor to verify the POE for themselves.

Q.2. We are familiar with all work. Is walkdown mandatory?

A.2. No one is required to attend the survey. It is done as a courtesy to bidding vendors.

Q.3. For the as-builts request in section 5.10, will background prints be made available that can be updated?

A.3. Background prints of the buildings will not be supplied by the court. The as-built for this project includes the connections from building to building and the POE entrance of the building.